

Plumbing

Items Evaluated	Possible Points	Contestant Number	Contestant Number	Contestant Number	Contestant Number	Contestant Number
		140	1301	141	938	284
DWV						
Slope - Dirty Arm Y/N	5	5	3	5	5	0
Slope - Lav Stub Out Y/N	5	5	4	5	2	5
Slope - W.C. 3" pipe Y/N	5	5	5	5	5	5
Clean out - 6" to center A.F.F.	10	6	2	2	6	6
Clean out - Direction	10	10	10	10	10	10
Copper						
Pressure test - pass/fail	10	10	10	10	10	10
Lav stub outs - 22" A.F.F.	5	5	0	0	1	1
Lav stub outs - 8" OC Spread	5	5	6	5	1	0
W.C. Stub out - 6" A.F.F.	10	5	0	5	6	4
Hose Bibb - 12" AFF	10	10	0	6	3	10
Solder Neatness	10	8	9	8	7	6
Resume	5	5	5	5	0	5

Project - up to 50 points Subtract 1 pt per 1/8" variation from plan measurements	50	31	37	15	23	13
SUBTOTAL	140	110	91	81	79	75
Penalties						
<i>Résumé Penalty (0 or -50 only)</i>		0	0	0	0	0
<i>Clothing Penalty (0 to -50)</i>		0	0	0	0	0
<i>Material Penalty (each piece -150)</i>		0	0	0	0	0
	140	110	91	81	79	75
ENTER NUMBER OF JUDGES (max 6):	1					
Final Score <i>(total/# judges)</i>	140.00	110.00	91.00	81.00	79.00	75.00
FINAL TOTAL		110.00	91.00	81.00	79.00	75.00